

Daily, Weekly, Monthly, Quarterly, and Annual Preventative Maintenance Examples

Daily Preventative Maintenance Example

Sample System Checks – Daily

Item	Tag	Set Point	Record Daily Value or Status
Pressures	Instrument air	PG1	>90 psig
	Sample pressure	PG2	>2 psig
	Probe vacuum	VG1	<10 inch Hg
Flows	Sample probe purge air	FR1	>80 psig
	Total sample flow	RM1	4-5 lpm
	NO _x analyzer flow	RM2	~1.5 lpm
	CO analyzer flow	RM3	~1.5 lpm
	O ₂ analyzer flow	RM4	~1.5 lpm
	Gas sample total flow	RM5	4-5 lpm
Visual checks	Room/enclosure temperature	HVAC	75°F, ±5°F
	Moisture sensor/filter	MS1	Clean and dry
	Cooler temp	GC1	Green light = okay
	Drain pump	DP1 and DP2	Turning approx. 6 rpm
	Sample line temp control	TC1	250°F, ±10°F

Note: this is only an example list - in this case for a source level extractive CEMS, and that the set points would be for this system only.

Weekly Preventative Maintenance Example

Sample System Checks – Weekly

Item	Value or Status (Completed, OK, Replaced)
Perform all daily checks.	
Perform manual calibration check.	
Check moisture sensor (MS1) and tubing downstream of sample conditioner for moisture. Remove and dry as necessary. Check sample conditioner (GC1) for proper operation.	
Verify sample line heater operation by checking current with amp meter.	

DAS Checks – Weekly

Item	Value or Status (Completed, OK, Replaced)
Check/change backup media (CD disk, tape, etc).	
If enabled, verify that automatic backups have occurred for the week.	
Verify there is sufficient disk for another week of data.	

Monthly Preventative Maintenance Example

Sample System Checks – Monthly

Item	Value or Status (Completed, OK, Replaced)
Perform all daily and weekly checks.	
Check sample pump (SP1); replace diaphragms and disks as needed, usually every 4 months.	
Check peristaltic pump tubing (DP1 and DP2), replace as necessary.	
Change desiccant media (DH1 and DH2).	
If equipped with an air compressor: <ol style="list-style-type: none"> 1. Check/change oil as needed. 2. Check for excessive water build-up 	
Check filter on shelter HVAC system. Clean or replace as needed, usually every 2-3 months.	
Check CGA/linearity cal gas bottle pressures > 500 psig. Order new gas bottles as needed keeping in mind the lead time may be several weeks.	

**CGA/Linearity Gas Cylinders

Quarterly Preventative Maintenance Example

Sample System Checks – Quarterly

Item	Value or Status (Completed, OK, Replaced)
Perform all daily, weekly, and monthly checks. Note that all routine maintenance is to be performed prior to the required quarterly audit test.	
If sample gas pressure (PG2) shows a decline, perform probe maintenance. Replace the filter element and clean the filter chamber as necessary. Replace O-rings. Verify probe box heater is operating. If flow is low, check sample pump (SP1).	
Verify and calibrate all CEMS alarm switches.	
The rear motor on the drain pumps (DP1/DP2) should be given two drops of #20 non-detergent oil. Do not over oil. Clean off any dust or dirt.	
Perform CEMS sample system leak check and flow balance procedure.	
Check ammonia scrubber (AS1). When deposits are visible 75% of the way up the length of the scrubber, scrubbing media needs to be replaced. Depending on concentration of NH ₃ and flowrate, media life may last 30,000 hrs.	
Perform general housekeeping duties inside shelter/cabinet. Dust/clean all equipment surfaces.	

Annual Preventative Maintenance Example

Sample System Checks – Annual

Item	Value or Status (Completed, OK, Replaced)
Perform all daily, weekly, monthly, quarterly, and semiannual checks. Note that all routine maintenance is to be performed prior to the required annual RATA.	
Replace sample pump (SP1) diaphragms.	
Inspect and clean thermoelectric cooler fan (GC1).	
Inspect and replace as needed Fluororubber, polypropylene, PVC, toalone, and Teflon joints.	

QA Audits – Annual

Item	Value or Status (Completed, OK, Replaced)
Perform any required annual RATA.	All testing completed on:
Check results for the RATA Bias Adjustment Factor and enter the BAF into the DAHS record field.	
For Appendix D reporting units: Perform annual fuel flowmeter accuracy check before close of the quarter in which due.	Analysis completed on: